<b>Notice</b>	e of Exemption	
То: 🗌	Office of Planning and Research P0 Box 3044, 1400 Tenth Street, Room 212 Sacramento, CA 958 12-3044	From (Applicant/Lead agency): Orange County Sanitation District 10844 Ellis Avenue Fountain Valley, CA 92708
	Orange County Clerk Recorder 601 North Ross Street Santa Ana, CA 92701-0238	
ŭ	•	Upgrades at Plant No. 2, Project No. SC19-06
•	Applicant: Orange County Sanitation District,	·
Project L	Location (specific): 22212 Brookhurst Street	Cross Street: Bushard Street
Project L	Location - City: <u>Huntington Beach</u>	Project Location — County: Orange
functional monitorin	lity of control and monitoring equipment for for	sting 12.47kV switchgear components to restore the our existing standby generators. Replaces control and otection relays, generator operator interface, digital age regulators and power monitors.
Name of	Public Agency Approving Project:	Orange County Sanitation District 10844 Ellis Avenue Fountain Valley, CA 92708
Name of	Person or Agency Carrying Out Project:	Orange County Sanitation District 10844 Ellis Avenue Fountain Valley, CA 92708
Exempt S	tatus: (check one)	
<ul><li>□ D</li><li>□ E</li><li>⊠ C</li></ul>	Ministerial (Sec. 21080(b)(1); 15268); Declared Emergency (Sec. 21080(b)(3); 15269(b) Emergency Project (Sec. 21080(b)(4); 15269(b) Categorical Exemption. State type and section retatutory Exemptions. State code number:	n(c)); number: <u>CEQA Guidelines Class 1 § 15301</u>
forth in C repair, ma no expans facilities of	alifornia Code of Regulations sections 15301. aintenance or minor alteration of existing posion of use beyond that existing at the time of	ot from CEQA under the Class 1 categorical exemptions set Section 15301 (Class 1) exempts from CEQA "the operationablic or private structures, facilities involving negligible of the lead agency's determination" including "(b) Existing sed to provide electric power, natural gas, sewerage, or other
		of the EPSA Standby Power Generator Control by upgrading use the capacity or otherwise expand the current use.
Lead Age Contact l	ency Person: Andrew Brown	_Area Code/Telephone/Extension: (714) 593-7052
Signature		9/8/23Title: Engineering Supervisor
	d by Lead Agency	

Form Number: PLN-F-110 Page 1 Revision Date: 10/18/12